

## **COMPRESSOR DATA SHEET**

## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Fixed Speed** 

MODEL DATA - FOR COMPRESSED AIR						
1	Manufacturer: Atlas	s Сорсо				
	Model Number: G15	125TM	Date:	6/29/2020		
2	X Air-cooled	Water-cooled	Type:	Screw		
			# of Stages:	1		
3*	Rated Capacity at Full Load Operating Pressure <sup>a, e</sup>		63	acfm <sup>a,e</sup>		
4	Full Load Operating Pressure <sup>b</sup>		125	psig <sup>b</sup>		
5	Maximum Full Flow Operating Pressure <sup>c</sup>		132	psig <sup>c</sup>		
6	Drive Motor Nominal Rating		20	hp		
7	Drive Motor Nominal Efficiency		91.2	percent		
8	Fan Motor Nominal Rating (if applicable)		0.7	hp		
9	Fan Motor Nominal Efficiency		N/A	percent		
10*	Total Package Input Power at Zero Flow <sup>e</sup>		5.3	kW <sup>e</sup>		
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>		15.7	$kW^d$		
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>e</sup>		24.9	kW/100 cfm <sup>e</sup>		
13	Isentropic Efficiency		60.30	Percent		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI websitefor a list of participants in the third party verification program: <u>www.cagi.org</u>

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.



Member

- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:
  - NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Compressed Air & Gas Institute	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
	$\underline{m}^3 / \underline{min}$	<u>ft3 / min</u>	%	% %	
	Below 0.5	Below 17.6	+/- 7	+/- 8	1
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
ROT 030.1	1.5 to 15	53 to 529.7	+/- 5	+/- 6	
	Above 15	Above 529.7	+/- 4	+/- 5	