COMPRESSOR DATA SHEET

Atlas Copco In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

MODEL DATA - FOR COMPRESSED AIR (Preliminary Data) Manufacturer: 1 **Atlas Copco** Model Number: GA75VSD+ Date: 3/20/2024 X Water-cooled Air-cooled 0 Type: 2 Screw # of Stages: 1 psig^b Full Load Operating Pressure^b 102 3 4 Drive Motor Nominal Rating 100 hp 96 Drive Motor Nominal Efficiency 5 percent Fan Motor Nominal Rating (if applicable) 6 NA hp 7 Fan Motor Nominal Efficiency NA percent Specific Power (kW/100 acfm)^d Capacity (acfm)^{a,d} Input Power (kW) 18.3 85.3 Max 465.7 62.1 354.3 17.5 8* 38.1 218.2 17.4 26.3 143.4 18.3 18.2 88.9 20.5 13.8 58.9 23.5 Total Package Input Power at Zero Flow^{c, d} 9* 0.0 kW Isentropic Effeciency 75.80 % 10 25.0 Specific Power (kW/100 ACFM) 20.0 11 15.0

Rotary Compressor: Variable Frequency Drive

 $0.0 \quad 25.0 \quad 50.0 \quad 75.0 \quad 100.0 \quad 125.0 \quad 150.0 \quad 175.0 \quad 200.0 \quad 225.0 \quad 250.0 \quad 275.0 \quad 300.0 \quad 325.0 \quad 375.0 \quad 400.0 \quad 425.0 \quad 450.0 \quad 475.0 \quad 500.0 \quad 525.0 \quad 500.0 \quad 525.0 \quad 500.0 \quad 5$

Capacity (ACFM)

Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.

Consult CAGI website for a list of participants in the third party verification program:

10.0

www.cagi.org

NOTES:

Member

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Compressed Air & Gas Institute	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
	<u>m³ / min</u>	<u>ft3 / min</u>	%	%	
	Below 0.5	Below 17.6	+/- 7	+/- 8	
ROT 030.1	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	
	Above 15	Above 529.7	+/- 4	+/- 5	
12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.					