

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

	MODEL DATA	- FOR COMPRESSI	ED AIR		
1	Manufacturer: Atlas Copco				
	Model Number: GA110VSD+	Date:	11/30/2020		
2	X Air-cooled Water-cooled	Type:	Screw		
		# of Stages:	1		
3	Full Load Operating Pressure ^b	102	psig ^b		
4	Drive Motor Nominal Rating	150	hp		
5	Drive Motor Nominal Efficiency	96	percent		
6	Fan Motor Nominal Rating (if applicable)	5.1	hp		
7	Fan Motor Nominal Efficiency	79	percent		
8*	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d		
	128.6 Max	731.1	17.6		
	97.5	572.7	17.0		
	75.0	447.9	16.7		
	46.0	265.7	17.3		
	28.3	148.2	19.1		
	21.6 Min	103.2	20.9		
9*	Total Package Input Power at Zero Flow ^{c, d}	0.0	kW		
10	Isentropic Effeciency	78.62	%		
11	25.0 15.0 10.0 0.0 25.050.075.0100.025.050.075.000.025.050.000.025.050.000.000.000.00				

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program:

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

	ne Flow Rate fied conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m³/min	ft3 / min	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	



ROT 030.1

Member

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data