## **COMPRESSOR DATA SHEET**



## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR (Preliminary Data)								
1	Manufacturer:	Atlas Copco						
2	Model Number:	GA110VSD+	Date:	3/20/2024				
	Air-cooled	X Water-cooled	Type: Screw					
			# of Stages:	1				
3	Full Load Operating Pressure <sup>b</sup>		102	$psig^b$				
4	Drive Motor Nominal Rating		150	hp				
5	Drive Motor Nominal Efficiency		96	percent				
6	Fan Motor Nominal Rating (if applicable)		NA	hp				
7	Fan Motor Nominal Efficiency		NA	percent				
8*	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	125.1	Max	722.5	17.3				
	93.8		565.1	16.6				
	70.2		435.4	16.1				
	41.6		254.4	16.4				
	24.8		138.2	17.9				
	18.7		94.0	19.9				
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>		0.0	kW				
10	Isentropic Effeciency		81.28	%				
11	25.0  20.0  15.0  10.0  0.0 25.0 50.075.0100.025.050.075.000.025.050.000.025.050.000.025.050.000.025.050.000.025.050.000.025.050.000.025.050.000.025.050.000.025.050.000.025.000.025.050.000.025.050.000.025.050.000.025.050.000.025.050.000.025.050.000.025.050.000.025.050.000.025.050.000.025.050.000.025.000.025.050.000.025.050.000.025.050.000.025.050.000.025.050.000.00							

<sup>\*</sup>For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.

Consult CAGI websitefor a list of participants in the third party verification program:

www.cagi.org

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

Member

b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity

- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}^3 / \mathbf{min}}$	<u>ft3 / min</u>	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 030.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.