

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

1	Manufacturer: Atlas Copco			
-	Model Number: GA75LVSD+	Date:	11/30/2020	
2	X Air-cooled Water-cooled	Type:	Screw	
		# of Stages:		
2	Full Load Operating Pressure ^b	-	1 psig ^b	
3 4	Drive Motor Nominal Rating	102 100		
5	Drive Motor Nominal Efficiency	96	hp percent	
6	Fan Motor Nominal Rating (if applicable)	2.6	hp	
7	Fan Motor Nominal Efficiency	79	percent	
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	93.8 Max	563.4	16.6	
	68.3	423.4	16.1	
8*	51.3	318.1	16.1	
	37.1	224.6	16.5	
	26.2	149.2	17.6	
	19.4 Min	101.2	19.2	
9*	Total Package Input Power at Zero Flow ^{c, d}	0.0	kW	
10	Isentropic Effeciency	82.27	%	
11	Note: Graph is only a Note: Y-Axis Scale, 10 to 5	175.0200.0225.0250.0275.0300.0325.0350.0 Capacity (ACFM) visual representation of the data in Secti 55, + 5kW/100acfm increments if necessary 6, 0 to 25% over maximum capacity		

For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. www.cagi.org

d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

Consult CAGI website for a list of participants in the third party verification program:

NOTES: Member

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 - b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
 - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- Compressed Air 8

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Compressed Air & Gas Institute	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power			
	$\underline{m^3 / \min}$	<u>ft3 / min</u>	%	%				
	Below 0.5	Below 17.6	+/- 7	+/- 8				
ROT 030.1	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%			
	1.5 to 15	53 to 529.7	+/- 5	+/- 6				
	Above 15	Above 529.7	+/- 4	+/- 5				
12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.								